



WE SERVE TO SAVE  
REGIONAL FIRE OFFICER  
GUJARAT STATE FIRE PREVENTION SERVICES SOUTH GUJARAT  
BARDOLI FIRE STATION , B/H.RAMJI MANDIR , BARDOLI  
E-MAIL :- Fireofficer@ymail.com Mob No.99743-35667

No.RFO-SFPS/F.No./1736 /NOC-Educational Building

Date :-04/10/2021

FORM B13  
(See sub rule (1) of rule 23)

**Fire Safety Certificate**

Certified That S.G.M. Shiroiya English School , Chhapra Road , Navsari-396445 , Gujarat Comprised Of Educational Building Comprised Of Educational Building Owned/ Occupied By S.G.M. Shiroiya English School Have Complied With The Fire Prevention And Fire Safety Requirements In Accordance With Section-18 And Verified By The Officers Concerned Of Fire Service On Dated:-03/10/2021 In The Presence Of Mr.Joy Thaliyachira K , Trustee The Building/Premises Is Fit For Occupancy With Effect From For A Period Of ( Form Date-04/10/2021 To Date-03/10/2022) One (01) Years In Accordance With Rules And Subject To Compliance Of Any Specific Liad By The Issuing Officer .

The administrative charge of N.O.C Rs.1000 x 02=2000/- has been recovered vide Chalan No-785, Dated:-04/10/2021 Inspection Charge Rs.2500 x 03=7500/- vide Chalan No-784 , Dated:-04/10/2021 The duration of the inspection report is valid up to (one year from the date of issue)


Note :- This NOC Should Be Cancelled Out Immediate If Found Not Obeying Of Any Instruction and Applicable CGDCR Act, Rules And Regulation For Fire Noc .

Issued Date :- 04/10/2021



  
P.B. Gadhvi  
Regional Fire Officer  
Surat.

Copy to , Chief Officer, Navsari Vijalpore Nagarpalika , Navsari For Information.

  
**PRINCIPAL**  
SGM Shiroiya Senior Secondary School  
Chhapra Road, Navsari - 396 445.



## SHIVANSH OHSE&Q CONSULTANCY FIRE SAFETY

FIRE PROTECTION CONSULTANT ON RECORD (LICENSE NO - FES / FPCOR /59)  
DISH AUTHORIZED TRAINING INSTITUTE NO. DISH/A-RULE/2020/1131

To,  
Management of the SGM School,  
Principal of the SGM School,

Sub: Fire Safety Certificate (Fire NOC) \_ Circular No. SFS/FN/85.1/55/2022

Please be informed that the circular issued from State Fire Prevention Services on date – 12<sup>th</sup> January 2022 and stated that all New Fire Safety Certificates (FIRE NOC) which are issued after 22 January 2021, are valid for next three years from the date of issued.

SGM school fire safety certificate (Fire NOC) was issued on date 4<sup>th</sup> October 2021. As per that circular SGM school fire NOC is valid for next three years from the date of issued and due date for the renewal will be 3<sup>rd</sup> October 2024.

We will take overall responsibility and ensure that SGM school fire safety certificate (fire NOC) will be renewed on time before it's expire.

This is for your kind information and record.



"SAFETY IS ALL ABOUT PEOPLE – NOBODY GET HURTS"

"YOUR SAFETY – OUR PRIORITY"

"YOUR SUCCESS – OUR DREAM"

PHONE NUMBER: +917016265799, +918980848226

EMAIL - [shivansh.ohseq@gmail.com](mailto:shivansh.ohseq@gmail.com) / [palpesh05@yahoo.com](mailto:palpesh05@yahoo.com)

OFFICE ADDRESS: Eru char Rasta, Opp. Naranlala College (Sitaramnagar Gate - Main Road)

Ta. Jalalpor, Pin code No. 396421, Dist - Navasari, Gujarat – INDIA

PRINCIPAL

SGM Shiroiya Senior Secondary School  
Chhapra Road, Navsari - 396 445.



rfo-sfps-surat@gujarat.gov.in



FORM B 13.3

**FIRE SAFETY CERTIFICATE RENEWAL (FSCR)**

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFOSRT/2023/00036023

Date: 03/07/2024

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFOSRT/2023/00036023/R1

Building Occupancy/Category: Educational (non-residential)

To,

Mr JOY THALIYACHIRA K  
1 Chhapra Road Navsari NAVSARI Navsari 396445  
Fire Region: Surat RFO  
Mobile No: 9426809993 Email ID: joythaliyachira@gmail.com

This has reference to your Application No.2024/00069939 dated 03/07/2024 for Fire Safety Certificate Renewal (FSCR) for the building/premise S G M Shiroiya English School (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: Navsari
5. Name of Block(s): A, B

The building/premise was inspected on **03/07/2024** and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on **03/07/2024**
2. Six monthly inspection was done on **03/07/2024**

The Fire Safety Certificate is renewed for a period of **two (2)** years upto **03/07/2026** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



**Digitally Verified**

Digitally verified by: Hiranng Shirishbhai Patel  
Fire Safety Officer - General (FSO-G)  
2021/001285

Date: 03/07/2024  
Time: 02:24 PM



FSCA/O/RFOSRT/2023/00036023/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at [www.gujfiresafetycop.in](http://www.gujfiresafetycop.in).

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.